





CE DECLARATION OF CONFORMITY

The undersigned Georgi Asenov Chimev as manager of Mareli Systems Ltd., address: No 18, Shar Planina str./Blagoevgrad 2700/ Bulgaria phone: +0359 887 756752,

Declare, in sole responsibility, that the product Pellet boilers Ecostar 12 / 18 / 24 / 30 / 35 kW is representative of the type SBN 12 / 18 / 24 / 30 / 35 kW, and designed for operation of solid fuel (pellets) and are produced in the factory of Mareli Systems Ltd, address: Industrial area, Simitli city 2730, Bulgaria. The products are produced in conditions implemented and maintained by the manufacturer for production control in accordance with for production control in accordance with:

- EN 303-5:2012 Heating devices, working with wood pellets for home use. Requirements and test methods.
 SD CEN/TS 15883:2009 Household devices for solid fuel. Testing methods for emissions.
 Directive 97/23/EC, introduced by "Regulation of essential requirements and conformity assessment of pressure equipments.
- Directive 2014/35/EC
- 5. BDS EN 60335-1; BDS EN 60335-2-102;
- 6. BDS EN 55014-1; BDS EN 61000-3-2; BDS EN 61000-3-3; BDS EN 55014-2.
- 7. EU 1189/2015 compliant.

The declaration is issued on the basis of Protocol for initial testing:

- Number 085 / 136 / 075 / DI 169 / 060
- Number 2-18-829
- Number 2a-18-829
 - Number 2EMC-18-829

ISSUED FROM:

ITEM Conuslt Ltd.

Address: Bulgaria, Sofia 1220, 8 "Istoria Slavianobulgarska" Blvd.

Address: Bulgaria, Stara Zagora 6000, 2 "Industrialna" str.

Specific requirements related to the use of the product:

In case of improper use or change of the product, this declaration is not valid.

The mark "CE" is used for first time on 13.08.2018.

I declare that I am aware of the responsibility that bears in accordance with the Article 313 of the Criminal Code of the Republic of Bulgaria.

As the manufacturer we declare under our sole responsability that the equipment follows the provisions of the Directives stated above.

PLACE:

SIMITLI

DATE:

04.12.2023

SIGNATURE:

МАРЕЛИ СИСТЕМС ЕООД

ОФИС:

Индустриална зона Симитли 2730, България Телефон: +359 74 850 821

MARELI SYSTEMS LTD

OFFICE:

Industrial area Simitli city 2730, Bulgaria

Tel.: +359 74 850 821

E-mail: info@mareli-systems.com Website: www. mareli-systems.com



"ITEM Consult" Ltd. Sofia 1220, 8 Istoria Slavianobulgarska Blvd

EEI ASSURANCE

NºDI-207/19.05.2020

Perлameнт/Regulation (EU) 2015/1187

Poduct: Manufacturer: Solid fuel pellet boiler Mareli Systems Ltd

Model:

ECOSTAR AUTO 24, cep. № BG 2304205033

Requested by:

Mareli Systems Ltd

Sofia, Lyulin district, bl. 821, ap.1

Stoking principle:

Automatic

Test Fuel:

Wood pellets (C1) Test report for the fuel № 12000/25.03.2019

Test procedure: Test report no:

EN 303 - 5:2012 169/30.04.2020

Fixed values:

F(1) CC BLF

 $\eta_{k \; nominal}$

Deduction regarding temperature controls 3 [%] Conversion coefficient for electricity consumption 2,5 [-] Biomass label factor 1,45 [-]

Test results:

 $\eta_{k \, minimum}$ M $\mathsf{GCV}_{\mathsf{mf}}$ H_{iw} H_{iwf} el_{max} el_{min} P_{SB}

Efficiency at nominal heat output 94,15 [%] Efficiency at minimum heat output 95,19 [%] Test fuel, moisture 4,39 [%] Test fuel, gross calorific value, moisture free 20,30 [MJ/kg] Test fuel, net heating value, with moisture 18,17 [Mj/kg] Test fuel, net heating value, moisture free 19,00 [Mj/kg] Electricity consumption at nominal heat output 0,09 [kW] Electricity consumption at minimum heat output 0,03 [kW] Electricity consumption in standby mode 0,001 [kW] Nominal heat output 24,11 [kW] Minimum heat output 7,94 [kW]

Calculations

 η_n η_p $\eta_{\text{el},n}$ η_{son} η_s F(2)

Efficiency at nominal output 88,14 [%] Efficiency at reduced output 89,11 [%] Electrical efficiency of solid fuel cogeneration boiler 0,00 [%] Seasonal space heating energy efficiency in active mode 88,97 [%] Seasonal space heating energy efficiency 85,00 [%] Auxiliary electricity consumption 0,0097 n/a Electrical efficiency of solid fuel cogeneration boilers 0,0000 n/a

Calculation of the Energy Efficiency index:

Energy Efficiency:

Energy Efficiency class:

125,03 A++

Energy Efficiency index (EEI)

125 ≤ EEI < 150

Изготвил:// *М*. Васи*в*ева

/M. Sc. L. Vasilev /

"ИТЕМ КОНСУЛТ" ЕООД



"ITEM - Consult" Ltd. Sofia 1220, bul. Istoriq Slavqnobulgarska. № 8

ECODESIGN REQUIREMENTS FOR SOLID FUEL BOILERS ACCORDING TO COMMISSION REGULATION (EU) 2015/1189 IMPLEMENTING DIRECTIVE 2009/125/EC OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL

№DI-209/19.05.2020

Trade mark:	Mareli Systems Ltd
Model:	ECOSTAR AUTO 24
Stoking mode:	Local heating pellet boiler with built-in hopper
Condensing boiler:	No
Solid fuel cogeneration boiler:	Combination boiler:

	Preferred fuel (only	Other suitabl	η _s (%)	Seasonal space heating emissions			
	one)	e fuel(s)		PM	OGC	CO	NOx
				mg/m³ at 10% O ₂			
Log wood, moisture content ≤25%	no	no					
Chipped wood, moisture content 15-35%	no	no					
Chipped wood, moisture content >35%	no	no					
Compressed wood in the form of pellets or briquettes	yes	no	85.00	20.86	11.64	163.97	158.69
Sawdust, moisture content≤50%	no	no					
Non-woody biomass	no	no					
Bituminous coal	no	no					
Brown coal (including briquettes)	no	no					
Coke	no	no					
Anthracite	no	no			-		
Blended fossil fuel briquettes	no	no					
Other fossil fuel	no	no					
Blended biomass (30-70%) fossil fuel briquettes	no	no					
Other blend of biomass and fossil fuel	no	no		-			7



"ITEM - Consult" Ltd. Sofia 1220, bul. Istoriq Slavqnobulgarska. № 8

Characteristics when operating with the preferred fuel only:

			_	preferred fuer only.			
Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Useful heat output			Useful efficiency				
At rated heat output	P _n	24.11	kW	At rated heat output	η _n	88.14	%
At (30%/50%) of rated heat output if it's applicable	Pp	7.94	kW	At (30%/50%) of rated otput if applicable	η_p	89.11	%
For solid fuel cogeneration boilers: Electrical efficiency				Auxiliary electricity consumption			
At rated heat output	$\eta_{el,n}$	N.A.	%	At rated heat output	el _{max}	0.09	kW
				At (30%/50%) of rated otput if applicable	el _{min}	0.03	kW
				Of incorporated secon emission abatement e if applicable	N.A.	kW	
				In standby mode	P _{SB}	0.001	kW

Contact details	Name and address of the manufacturer or its authorised representative		
Telephone: +359 888 406 956	"Mareli Systems"Ltd Address: Sofia, Bulgaria, Lyulin district, bl.		
	821, ap. 1 Telephone: +359 888 406 956		

Prepared by:

/M. Vasileva/

"ИТЕМ Консулт" Е00Д

Manager

/M Sc. I. Vasiles